

TAMILNADU FIRE AND RESCUE SERVICE DEPARTMENT
FIRE AND RESCUE STATION, SEMBIUM

Lic. No. 301/V/2025

Date : 12.08.2025

NO OBJECTION CERTIFICATE

**Sub : Fire and rescue Service Department – Fire and Rescue Station – Sembium
Issue of No Objection Certificate – Functioning the School – Reg.**

**Ref: 1) G.O. No. 122 School Education (2) Department Dt : 14.09.2004
2) G.O. No. 123 School Education (2) Department Dt : 14.09.2004.
3) G.O. No. 639 Home Department (POLICE XVII) Dt : 21.11.2024
4) Application Received from CORRESPONDENT, ARCHBISHOP GEORGE
PUBLIC SCHOOL, No:15, LAKSMANAN NAGAR MAIN ROAD, PERAVALLUR,
CHENNAI 600 082, Dated: 08.08.2025.**

Based on the reference in the G.Os cited 1 & 2 Mr. S.PARAMESWARAN, STATION OFFICER, SEMBIUM, inspected the school in the name of "ARCHBISHOP GEORGE PUBLIC SCHOOL" Situated at No:15, LAKSMANAN NAGAR MAIN ROAD, PERAVALLUR, CHENNAI 600 082 on 11.08.2025 Considering on Fire and Rescue view there is No Objection for functioning the School in the above mentioned address.

As per Col. 13 of appendix V to the under section 13 of the Act

1. This License is valid for THREE YEAR from the date of issue.
2. Regular License has to be obtained from competent authority
3. All the fire extinguishers have to be recharged and maintained periodically as per code practice in 2190 / 1992.
4. Hose reel system should be Maintained Properly.
5. If there is any deviation from the Govt . rule and Act the LICENSE issued will stand cancelled.
6. Firefighting trained employee must be available in the premises to operate the Equipment.



**To: CORRESPONDENT,
ARCHBISHOP GEORGE PUBLIC SCHOOL,
No:15, LAKSMANAN NAGAR MAIN ROAD,
PERAVALLUR, CHENNAI 600 082.**

**STATION OFFICER
FIRE & RESCUE STATION
SEMBIUM, CHENNAI-600 011.**

Copy to Joint Director – Northern Region.
Copy to District Officer - North District.